

List of PV suncell inverters complying with the requirements in TF 3.2.1

Manufacturer	Nationality	Designation	Power AC	No. of phases	Current per fase	Factory settings	Approval	Expiry	Firmware	TF 3.2.1	EN 50438-DK	VDE-AR-N-4105	CE-compliant	Energinet.dk file (Acadre)	Comments	
	[Country]	[type]	[kW]	[no.]	[A]		[date]	[date]	[version]	[✓]	[✓]	[✓]	[✓]	[✓]		
ABB Oy Drives	Finland	PVS300-TL-3300W-2	3.3	1	14.3	Denmark	27 March 2012	NTR	CSSIA006_0061	✓	-	✓	✓	10/7230	If limited to max 3 kW it is done from the factory	
Alpinengineering GmbH	Germany	Alpinsun Peak 3000	3	1	16	Denmark	15 February 2012	NTR	NET11_ENS_2.9	✓	-	✓	✓	11/1705		
		Alpinsun Peak 3600	3.6	1	16	Denmark	15 February 2012	NTR	NET11_ENS_2.9	✓	-	✓	✓	11/1705		
Altenergy Power Systems inc.	China	YC200-EU	0.22	1	1	Denmark	20 June 2012	NTR	-	✓	-	✓	✓	12/1062	Max 3.68kVA per plant	
Anhui EHE new Energy Tech Co Ltdt	China	EHE-N1.5KTL	1.5	1	6.9	Denmark	3 October 2011	NTR	V11.10	✓	✓	-	✓	11/1739		
		EHE-N2KTL	2	1	10	Denmark	3 October 2011	NTR	V11.10	✓	✓	-	✓	11/1739		
		EHE-N2K5	2.5	1	11	Denmark	11 October 2011	NTR	V11.10	✓	✓	-	✓	11/1739		
		EHE-N3KTL	3	1	15	Denmark	3 October 2011	NTR	V11.10	✓	✓	-	✓	11/1739		
		EHE-N4KTL	4	1	16	Denmark	14 February 2012	NTR	V11.10	✓	✓	-	✓	11/1879	Limited to max 16 A/phase or 3kW / 13A/phase in configuration software and protected by installer password	
		EHE-N5KTL	5	3	8	Denmark	30 August 2012	NTR	V11.10	✓	✓	-	✓	11/1757		
		EHE-N6KTL	6	3	9	Denmark	30 August 2012	NTR	V11.10	✓	✓	-	✓	11/1757		
Aros Solar Technology	Italy	SIRIO EVO 1500	1.5	1	6.6	Denmark	31 January 2012	30 September 2012	02.00	✓	-	✓	✓	10/5724	Expire date will be "NTR", when the documentation VDE-AR-N-4105 appendix F3 and F4 are received from the manufacture	
		SIRIO EVO 2000	2	1	8.7	Denmark	31 January 2012	30 September 2012	02.00	✓	-	✓	✓	10/5724	Expire date will be "NTR", when the documentation VDE-AR-N-4105 appendix F3 and F4 are received from the manufacture	
		SIRIO EVO 3000	3	1	13	Denmark	31 January 2012	30 September 2012	02.00	✓	-	✓	✓	10/5724	Expire date will be "NTR", when the documentation VDE-AR-N-4105 appendix F3 and F4 are received from the manufacture	
		SOLIA 6000	6	3	8.7	Denmark	9 March 2012	NTR	-	✓	-	✓	✓	10/5724		
		SIRIO 10000P	10	3	14.5	Denmark	31 January 2012	NTR	-	✓	-	✓	✓	10/5724		
Beijing Kinglong New Energy Technology Co.,Ltd	China	KLNE Sunteams 1500	1.5	1	6.5	Denmark	2 January 2012	NTR	V5.03 & V8.13	✓	✓	-	✓	11/1714		
		KLNE Sunteams 2000	2	1	9	Denmark	2 January 2012	NTR	V5.03 & V8.13	✓	✓	-	✓	11/1714		
		KLNE Sunteams 3000	3	1	14	Denmark	2 January 2012	NTR	V5.03 & V8.13	✓	✓	-	✓	11/1714		
		KLNE Sunteams 10000	10	3	15	Denmark	24 April 2012	NTR	V5.03 & V8.13	✓	-	✓	✓	11/1714		
		KLNE Sunteams 12000	12	3	18	Denmark	24 April 2012	NTR	V5.03 & V8.13	✓	-	✓	✓	11/1714		
		KLNE Sunteams 15000	15	3	22	Denmark	24 April 2012	NTR	V5.03 & V8.13	✓	-	✓	✓	11/1714		
		Solartec 1500	1.5	1	9	Denmark	14 May 2012	NTR	V5.03 & V8.13	✓	✓	-	✓	11/1714		
		Solartec 2000	2	1	12	Denmark	14 May 2012	NTR	V5.03 & V8.13	✓	✓	-	✓	11/1714		
		Solartec 2500	2.5	1	16	Denmark	14 May 2012	NTR	V5.03 & V8.13	✓	✓	-	✓	11/1714		
		Solartec 3000	3	1	16	Denmark	14 May 2012	NTR	V5.03 & V8.13	✓	✓	-	✓	11/1714		
		Solartec 3600	3.6	1	16	Denmark	14 May 2012	NTR	V5.03 & V8.13	✓	✓	-	✓	11/1714		
B&B Power Co Ltd	China	SF 1500TL	1.5	1	8.6	Denmark	24 August 2012	NTR	-	✓	✓	-	✓	12/1241		
		SF 2200TL	2.2	1	11	Denmark	24 August 2012	NTR	-	✓	✓	-	✓	12/1241		
		SF 3000TL	3	1	15	Denmark	24 August 2012	NTR	-	✓	✓	-	✓	12/1241		
Bentimex	China	JSI-3000TL	3	1	13	Denmark	1 January 2011	NTR	-	✓	✓	-	✓	10/7186		
Boema	China	BNI 1.5	1.5	1	8.7	Denmark	27 September 2012	1 December 2012	-	✓	(✓)	-	✓	12/1765		
		BNI 2.2	2.2	1	11	Denmark	27 September 2012	1 December 2012	-	✓	(✓)	-	✓	12/1765		
		BNI 3.0	3	1	15	Denmark	27 September 2012	1 December 2012	-	✓	(✓)	-	✓	12/1765		
Carlo Gavazzi	Italien	ISMG 1 45DE	3.8	1	14.3	Denmark	26 March 2012	NTR	Seq V1.33 / Curv 1.31	✓	-	✓	✓	11/1238		
		ISMG 1 45DE- PL3	2.99	1	13	Denmark	30 May 2012	NTR	Seq V1.33 / Curv 1.31	✓	-	✓	✓	11/1238		
Centrosolar AG	Germany	Powerstocc Excellent 3.0 DCS	3	1	13	Denmark	22 May 2012	NTR	V04.00	✓	-	✓	✓	11/2270		
		Powerstocc Excellent 3.6 DCS	3.6	1	15.7	Denmark	22 May 2012	NTR	V04.00	✓	-	✓	✓	11/2270		
		Powerstocc Excellent 4.2 DCS	4.2	3	6.1	Denmark	22 May 2012	NTR	V04.00	✓	-	✓	✓	11/2270		
		Powerstocc Excellent 5.5 DCS	5.5	3	8	Denmark	22 May 2012	NTR	V04.00	✓	-	✓	✓	11/2270		
		Powerstocc Excellent 7.0 DCS	7	3	10	Denmark	22 May 2012	NTR	V04.00	✓	-	✓	✓	11/2270	By factory selection "DK" limited to 6kW	
		Powerstocc Excellent 7.0 AD	7	3	10	Denmark	22 May 2012	NTR	V04.00	✓	-	✓	✓	11/2270	By factory selection "DK" limited to 6kW	
		Powerstocc Excellent 8.3 DCS	8.3	3	12	Denmark	22 May 2012	NTR	V04.00	✓	-	✓	✓	11/2270	If limited to max 6 kW it has to be done in the configuration software and protected by installer password	
		Powerstocc Excellent 8.3 AD	8.3	3	12	Denmark	22 May 2012	NTR	V04.00	✓	-	✓	✓	11/2270	If limited to max 6 kW it has to be done in the configuration software and protected by installer password	
		Powerstocc Excellent 10.1 DCS	10	3	14.6	Denmark	22 May 2012	NTR	V04.00	✓	-	✓	✓	11/2270	If limited to max 6 kW it has to be done in the configuration software and protected by installer password	
		Powerstocc Excellent 10.1 AD	10	3	14.6	Denmark	22 May 2012	NTR	V04.00	✓	-	✓	✓	11/2270	If limited to max 6 kW it has to be done in the configuration software and protected by installer password	
		Powerstocc Excellent 1200	1.6	1	7	Denmark	23 December 2011	NTR	V04.00	✓	-	✓	✓	11/2270		
		Powerstocc Excellent 2000	1.6	1	7	Denmark	23 December 2011	NTR	-	1.67	✓	-	✓	11/2270		
		Powerstocc Excellent 3000	2.8	1	12.1	Denmark	23 December 2011	NTR	-	1.67	✓	-	✓	11/2270		
		Powerstocc Excellent 4000	3.3	1	14.3	Denmark	23 December 2011	NTR	-	1.67	✓	-	✓	11/2270		
Danfoss Solar Inverters A/S	Denmark	ULX 1800	1.6	1	7	Denmark	23 December 2011	NTR	-	1.67	✓	-	✓	10/4857		
		ULX 1800	1.6	1	7	Denmark	1 October 2012	NTR	-	1.91	✓	✓	-	✓	10/4857	
		ULX 3000	2.8	1	12.1	Denmark	23 December 2011	NTR	-	1.67	✓	-	✓	✓	10/4857	
		ULX 3000	2.8	1	12.1	Denmark	1 October 2012	NTR	-	1.91	✓	✓	-	✓		

List of PV suncell inverters complying with the requirements in TF 3.2.1

Manufacturer	Nationality	Designation	Power AC	No. of phases	Current per fase	Factory settings	Approval	Expiry	Firmware	TF 3.2.1	EN 50438-DK	VDE-AR-N-4105	CE-compliant	Energinet.dk file (Acade)	Comments
	[Country]	[type]	[kW]	[no.]	[A]		[date]	[date]	[version]	[✓]	[✓]	[✓]	[✓]	[✓]	
		TLX+ 10k	10	3	15	Denmark LV1/LV2	16 January 2012	NTR	2.13	✓ - ✓ ✓	10/4857	If limited to max 6 kW it has to be done in the configuration software and protected by installer password			
		TLX+ 10k	10	3	15	Denmark EN50438	23 July 2012	NTR	3.30	✓ - ✓ ✓	10/4857	If limited to max 6 kW it has to be done in the configuration software and protected by installer password			
		TLX+ 12.5k	12.5	3	19	Denmark LV1/LV2	16 January 2012	NTR	2.13	✓ - ✓ ✓	10/4857	If limited to max 6 kW it has to be done in the configuration software and protected by installer password			
		TLX+ 12.5k	12.5	3	19	Denmark EN50438	23 July 2012	NTR	3.30	✓ - ✓ ✓	10/4857	If limited to max 6 kW it has to be done in the configuration software and protected by installer password			
		TLX+ 15k	15	3	22	Denmark LV1/LV2	16 January 2012	NTR	2.13	✓ - ✓ ✓	10/4857	If limited to max 6 kW it has to be done in the configuration software and protected by installer password			
		TLX+ 15k	15	3	22	Denmark EN50438	23 July 2012	NTR	3.30	✓ - ✓ ✓	10/4857	If limited to max 6 kW it has to be done in the configuration software and protected by installer password			
		TLX Pro+ 6k	6	3	9	Denmark LV1/LV2	16 January 2012	NTR	2.13	✓ - ✓ ✓	10/4857				
		TLX Pro+ 6k	6	3	9	Denmark EN50438	23 July 2012	NTR	3.30	✓ - ✓ ✓	10/4857				
		TLX Pro+ 8k	8	3	12	Denmark LV1/LV2	16 January 2012	NTR	2.13	✓ - ✓ ✓	10/4857	If limited to max 6 kW it has to be done in the configuration software and protected by installer password			
		TLX Pro+ 8k	8	3	12	Denmark EN50438	23 July 2012	NTR	2.13	✓ - ✓ ✓	10/4857	If limited to max 6 kW it has to be done in the configuration software and protected by installer password			
		TLX Pro+ 10k	10	3	15	Denmark LV1/LV2	16 January 2012	NTR	2.13	✓ - ✓ ✓	10/4857	If limited to max 6 kW it has to be done in the configuration software and protected by installer password			
		TLX Pro+ 10k	10	3	15	Denmark EN50438	23 July 2012	NTR	3.30	✓ - ✓ ✓	10/4857	If limited to max 6 kW it has to be done in the configuration software and protected by installer password			
		TLX Pro+ 12.5k	12.5	3	19	Denmark LV1/LV2	16 January 2012	NTR	2.13	✓ - ✓ ✓	10/4857	If limited to max 6 kW it has to be done in the configuration software and protected by installer password			
		TLX Pro+ 12.5k	12.5	3	19	Denmark EN50438	23 July 2012	NTR	3.30	✓ - ✓ ✓	10/4857	If limited to max 6 kW it has to be done in the configuration software and protected by installer password			
		TLX Pro+ 15k	15	3	22	Denmark LV1/LV2	16 January 2012	NTR	2.13	✓ - ✓ ✓	10/4857	If limited to max 6 kW it has to be done in the configuration software and protected by installer password			
		TLX Pro+ 15k	15	3	22	Denmark EN50438	23 July 2012	NTR	3.30	✓ - ✓ ✓	10/4857	If limited to max 6 kW it has to be done in the configuration software and protected by installer password			
DassTech	Korea	DSP-123K2	3	1	13	Denmark	06 March 2012	NTR		✓ - ✓ ✓	12/333				
Delta Energy Systems	Germany	SOLIVIA 2.5 EU G4 TR	2.5	1	11.2	Denmark	2 January 2012	NTR	1.2.x	✓ - ✓ ✓	11/275				
		SOLIVIA 3.0 EU G4 TR	3	1	13.5	Denmark	2 January 2012	NTR	1.2.x	✓ - ✓ ✓	11/275				
		SOLIVIA 3.3 EU G4 TR	3.3	1	14.9	Denmark	2 January 2012	NTR	1.2.x	✓ - ✓ ✓	11/275				
		SOLIVIA 3.6 EU G4 TR	3.6	1	15.7	Denmark	3 August 2012	NTR	1.2.x	✓ - ✓ ✓	11/275				
		SOLIVIA 11 EU G4 TR	11	3	15.9	Denmark	20 February 2012	NTR	1.2.x	✓ - ✓ ✓	11/275				
		SOLIVIA 15 EU G4 TL	15	3	21.8	Denmark	20 February 2012	NTR	1.2.x	✓ - ✓ ✓	11/275				
		SOLIVIA 20 EU G4 TL	20	3	28.9	Denmark	20 February 2012	NTR	1.2.x	✓ - ✓ ✓	11/275				
		3 X SOLIVIA 5.0 EU T4 TL	15	3	24.5	Denmark	04 October 2012	NTR	0012	✓ - ✓ ✓	11/2438	Only in combination of 3 inverters with internal communication			
Diehl AKO	Germany	PLATINUM 2100H	2.1	1	10.5	Denmark	09 March 2012	NTR	GUI 1.XX	✓ - ✓ ✓	11/2202				
		PLATINUM 3000H	3	1	15.2	Denmark	09 March 2012	NTR	GUI 1.XX	✓ - ✓ ✓	11/2202				
		PLATINUM 4000H	3.8	1	16	Denmark<16A	27 July 2012	NTR	GUI 1.XX	✓ - ✓ ✓	11/2202	Limited to 16A/phase by factory			
		PLATINUM 4600H	4.4	1	16	Denmark<16A	27 July 2012	NTR	GUI 1.XX	✓ - ✓ ✓	11/2202	Limited to 16A/phase by factory			
		PLATINUM 3801 TLD	3.33	1	14.3	Denmark	24 February 2012	NTR	1.2	✓ - ✓ ✓	11/2202				
		PLATINUM 3800 TLD	3.68	1	16	Denmark	24 February 2012	NTR	1.2	✓ - ✓ ✓	11/2202				
		PLATINUM 13000 TLD	12.36	3	17.8	Denmark	23 January 2012	NTR	1.2	✓ - ✓ ✓	11/2202				
		PLATINUM 16000 TLD	15	3	21.7	Denmark	23 January 2012	NTR	1.2	✓ - ✓ ✓	11/2202				
		PLATINUM 19000 TLD	18	3	26	Denmark	23 January 2012	NTR	1.2	✓ - ✓ ✓	11/2202				
		PLATINUM 22001 TLD	20	3	28.9	Denmark	23 January 2012	NTR	1.2	✓ - ✓ ✓	11/2202				
		PLATINUM 22000 TLD	20.7	3	29.9	Denmark	23 January 2012	NTR	1.2	✓ - ✓ ✓	11/2202				
		PLATINUM 11000 TL3R	10	3	14.5	Denmark	30 May 2012	NTR	RFP-802D010-29-14-S	✓ - ✓ ✓	11/2202				
		PLATINUM 13000 TL3R	12.4	3	18	Denmark	30 May 2012	NTR	RFP-802D013-29-14-S	✓ - ✓ ✓	11/2202				
		PLATINUM 17000 TL3R	16.5	3	23.9	Denmark	30 May 2012	NTR	RFP-802D017-29-14-S	✓ - ✓ ✓	11/2202				
		PLATINUM 20000 TL3R	19.2	3	27.8	Denmark	30 May 2012	NTR	RFP-802D020-29-14-S	✓ - ✓ ✓	11/2202				
		PLATINUM 7000 R3-MDX	6	3	8.7	Denmark	27 July 2012	NTR	2.0	✓ - ✓ ✓	11/2202				
		PLATINUM 9000 R3-MDX	8.2	3	11.6	Denmark	27 July 2012	NTR	2.0	✓ - ✓ ✓	11/2202				
		PLATINUM 11000 R3-MDX	10.2	3	14.5	Denmark	27 July 2012	NTR	2.0	✓ - ✓ ✓	11/2202				
		PLATINUM 14000 R3-MDX	12.8	3	18.9	Denmark	27 July 2012	NTR	2.0	✓ - ✓ ✓	11/2202				
		PLATINUM 16000 R3-MDX	15.3	3	22	Denmark	27 July 2012	NTR	2.0	✓ - ✓ ✓	11/2202				
Effekta Regeltechnik GmbH	Germany	ES 2200	2	1	8.7	Denmark	28 March 2012	NTR	PV000002	✓ - ✓ ✓	12/634				
		ES 3300	3	1	13	Denmark	28 March 2012	NTR	PV000002	✓ - ✓ ✓	12/634				
		ES 5000-2K	5	1	8.7	Denmark	17 April 2012	NTR	PV000002	✓ - ✓ ✓	12/634	Limited to max 2 kW in configuration software and protected by installer password			
		ES 5000-3K	5	1	13	Denmark	17 April 2012	NTR	PV000002	✓ - ✓ ✓	12/634	Limited to max 3 kW in configuration software and protected by installer password			
Eltek Renewable	Norge	Theia 2.0HE-t	2	1	9	Denmark	01 May 2012	NTR	GUI 1.XX	✓ - ✓ ✓	12/792				
		Theia 2.9HE-t	2.9	1	13	Denmark	01 May 2012	NTR	GUI 1.XX	✓ - ✓ ✓	12/792				
		Theia 3.8HE-t	3.8	1	16	Denmark	07 May 2012	NTR	GUI 1.XX	✓ - ✓ ✓	12/792	Limited to max 16 A/phase in configuration software and protected by installer password			
		Theia 4.4HE-t	4.4	1	16	Denmark	07 May 2012	NTR	GUI 1.XX	✓ - ✓ ✓	12/792	Limited to max 16 A/phase in configuration software and protected by installer password			
Enecsys	England	SMI-D480W-60	0.45	1	1	Denmark	20 March 2012	NTR	H_1_4h						

List of PV suncell inverters complying with the requirements in TF 3.2.1

Manufacturer	Nationality	Designation	Power AC	No. of phases	Current per fase	Factory settings	Approval	Expiry	Firmware	TF 3.2.1	EN 50438-DK	VDE-AR-N-4105	CE-compliant	Energinet.dk file (Acadre)	Comments
	[Country]	[type]	[kW]	[no.]	[A]		[date]	[date]	[version]	[✓]	[✓]	[✓]	[✓]	[✓]	
		CL 36.0	36	3	52.2	Denmark	31 January 2012	NTR	5.8.0 / 1.4.11 / 3.5.5 / 1.0.0	✓	-	✓	✓	12/88	
		CL 48.0	48	3	69.6	Denmark	31 January 2012	NTR	5.8.0 / 1.4.11 / 3.5.5 / 1.0.0	✓	-	✓	✓	12/88	
		CL 60.0	60	3	87	Denmark	31 January 2012	NTR	5.8.0 / 1.4.11 / 3.5.5 / 1.0.0	✓	-	✓	✓	12/88	
GESolar	China	GES-3K3TL	3	1	13	Denmark	13 December 2011	NTR		✓	✓	-	✓	11/2463	
Guangzhou Sanjing Electric CO., LTD (SAJ)	China	GFC-TL 1.5K	1.65	1	8.5	Denmark	2 February 2012	NTR		✓	✓	-	✓	11/2373	
		GFC-TL 3KA	3	1	15	Denmark	2 February 2012	NTR		✓	✓	-	✓	11/2373	
		GFC-TL 3KB	3	1	15	Denmark	28 June 2012	NTR		✓	✓	-	✓	11/2373	
		Sununo-TL 1.5K	1.65	1	8.5	Denmark	2 February 2012	NTR		✓	✓	-	✓	11/2373	
		Sununo-TL 3KA	3	1	15	Denmark	2 February 2012	NTR		✓	✓	-	✓	11/2373	
		Sununo-TL 3KB	3	1	15	Denmark	28 June 2012	NTR		✓	✓	-	✓	11/2373	
IBC Solar AG	Germany	IBC Servermaster 1650	1.6	1	7	Denmark	16 April 2012	NTR	1.67	✓	-	✓	✓	12/590	
		IBC ServerMaster 2750	2.8	1	12.1	Denmark	16 April 2012	NTR	1.67	✓	-	✓	✓	12/590	
		IBC ServerMaster 3300	3.3	1	14.3	Denmark	16 April 2012	NTR	1.67	✓	-	✓	✓	12/590	
		IBC Servermaster 6000TL +	6	3	9	Denmark	09 March 2012	NTR	2.13	✓	-	✓	✓	12/590	
		IBC Servermaster 6000TL Pro +	6	3	9	Denmark	09 March 2012	NTR	2.13	✓	-	✓	✓	12/590	
		IBC Servermaster 8000TL	8	3	12	Denmark	09 March 2012	NTR	2.13	✓	-	✓	✓	12/590	
		IBC Servermaster 8000TL +	8	3	12	Denmark	09 March 2012	NTR	2.13	✓	-	✓	✓	12/590	
		IBC Servermaster 8000TL Pro +	8	3	12	Denmark	09 March 2012	NTR	2.13	✓	-	✓	✓	12/590	
		IBC Servermaster 10000TL	10	3	15	Denmark	09 March 2012	NTR	2.13	✓	-	✓	✓	12/590	
		IBC Servermaster 10000TL +	10	3	15	Denmark	09 March 2012	NTR	2.13	✓	-	✓	✓	12/590	
		IBC Servermaster 10000TL Pro +	10	3	15	Denmark	09 March 2012	NTR	2.13	✓	-	✓	✓	12/590	
		IBC Servermaster 12500TL	12.5	3	19	Denmark	09 March 2012	NTR	2.13	✓	-	✓	✓	12/590	
		IBC Servermaster 12500TL +	12.5	3	19	Denmark	09 March 2012	NTR	2.13	✓	-	✓	✓	12/590	
		IBC Servermaster 12500TL Pro +	12.5	3	19	Denmark	09 March 2012	NTR	2.13	✓	-	✓	✓	12/590	
		IBC Servermaster 15000TL	15	3	22	Denmark	09 March 2012	NTR	2.13	✓	-	✓	✓	12/590	
		IBC Servermaster 15000TL +	15	3	22	Denmark	09 March 2012	NTR	2.13	✓	-	✓	✓	12/590	
		IBC Servermaster 15000TL Pro +	15	3	22	Denmark	09 March 2012	NTR	2.13	✓	-	✓	✓	12/590	
Involar	China	MAC 250	0.235	1	1.02	Denmark	10 January 2012	NTR		✓	✓	-	✓	11/1939	Max 3.68kVA per plant
i-Energy Corporation Ltd	Taiwan	GT260	0.21		0.92	Denmark	09 July 2012	NTR	DDP240UEB_CVDE_ARN4105_V01 10_DDP_A02001_S:	✓	-	✓	✓	12/1183	Max 3.68kVA per plant
Jiangsu Goodwe Power Supply Technology Co Ltd	China	GW1500-SS	1.5	1	8	Denmark	07 March 2012	NTR		✓	✓	-	✓	12/471	
		GW2000-SS	2	1	10	Denmark	07 March 2012	NTR		✓	✓	-	✓	12/471	
		GW3000-SS	3	1	15	Denmark	07 March 2012	NTR		✓	✓	-	✓	12/471	
		GW3600D-DK	3.6	1	16	Denmark	28 September 2012	NTR		✓	✓	-	✓	12/471	
		GW06K-DT	6	3	10	Denmark	5 September 2012	NTR		✓	✓	-	✓	12/471	
		GW10K-DT	10	3	17	Denmark	21 May 2012	NTR		✓	✓	-	✓	12/471	
		GW12K-DT	12	3	19	Denmark	21 May 2012	NTR		✓	✓	-	✓	12/471	
		GW15K-DT	15	3	25	Denmark	21 May 2012	NTR		✓	✓	-	✓	12/471	
		GW17K-DT	17	3	25	Denmark	21 May 2012	NTR		✓	✓	-	✓	12/471	
Jiangsu Zeversolar New Energy Co., Ltd	China	Volta VL1500	1.5	1	7.5	Denmark	10 July 2012	NTR	V1.00	✓	✓	-	✓	12/583	
		Volta VL3000	3.0	1	15	Denmark	10 July 2012	NTR	V1.00	✓	✓	-	✓	12/583	
Kaco	Germany	Powador 3200	2.6	1	11.3	Denmark	31 May 2012	NTR	ARM 4.76 / DSP 4.70	✓	-	✓	✓	11/1869	
		Powador 4400	3.6	1	15.6	Denmark	31 May 2012	NTR	ARM 4.76 / DSP 4.70	✓	-	✓	✓	11/1869	
		Powador 2002	1.65	1	7.2	Denmark	31 May 2012	NTR	ARM 4.76 / DSP 4.70	✓	-	✓	✓	11/1869	
		Powador 3002	2.5	1	10.9	Denmark	31 May 2012	NTR	ARM 4.76 / DSP 4.70	✓	-	✓	✓	11/1869	
		Powador 4202	3.5	1	15.2	Denmark	31 May 2012	NTR	ARM 4.76 / DSP 4.70	✓	-	✓	✓	11/1869	
		Powador 10.0 TL3	9.0	3	13.0	Denmark	31 January 2012	NTR	ARM 1.26 / AC 1.20 / DC 1.24	✓	-	✓	✓	11/1869	If limited to max 6 kW it has to be done in the configuration software and protected by installer password
		Powador 12.0 TL3	10.0	3	14.5	Denmark	31 January 2012	NTR	ARM 1.26 / AC 1.20 / DC 1.24	✓	-	✓	✓	11/1869	If limited to max 6 kW it has to be done in the configuration software and protected by installer password
		Powador 14.0 TL3	12.5	3	18.1	Denmark	31 January 2012	NTR	ARM 1.26 / AC 1.20 / DC 1.24	✓	-	✓	✓	11/1869	If limited to max 6 kW it has to be done in the configuration software and protected by installer password
Kostal	Germany	Piko 3.0	3	1	13	Denmark	3 January 2012	NTR	V04.00	✓	-	✓	✓	11/1239	
		Piko 3.6	3.6	1	15.7	Denmark	3 January 2012	NTR	V04.00	✓	-	✓	✓	11/1239	
		Piko 4.2	4.2	3	6.1	Denmark	3 January 2012	NTR	V04.00	✓	-	✓	✓	11/1239	
		Piko 5.5	5.5	3	8	Denmark	3 January 2012	NTR	V04.00	✓	-	✓	✓	11/1239	
		Piko 7.0	7	3	10	Denmark	26 April 2012	NTR	V04.00	✓	-	✓	✓	11/1239	By factory selection "DK" limited to 6kW
		Piko 7.0 AD	7	3	10	Denmark	26 April 2012	NTR	V04.00	✓	-	✓	✓	11/1239	By factory selection "DK" limited to 6kW
		Piko 8.3	8.3	3	12	Denmark	3 January 2012	NTR	V04.00	✓	-	✓	✓	11/1239	If limited to max 6 kW it has to be done in the configuration software and protected by installer password
		Piko 8.3 AD	8.3	3	12	Denmark	3 January 2012	NTR	V04.00	✓	-	✓	✓	11/1239	If limited to max 6 kW it has to be done in

List of PV suncell inverters complying with the requirements in TF 3.2.1

Manufacturer	Nationality	Designation	Power AC	No. of phases	Current per fase	Factory settings	Approval	Expiry	Firmware	TF 3.2.1	EN 50438-DK	VDE-AR-N-4105	CE-compliant	Energinet.dk file (Acadre)	Comments
	[Country]	[type]	[kW]	[no.]	[A]		[date]	[date]	[version]	[✓]	[✓]	[✓]	[✓]	[✓]	
Mitsubishi Electric Ltd	Germany	PV-S2600	2.9	1	11.3	Denmark	30 May 2012	NTR	4.01 / 4.05	✓ - ✓	- ✓	12/913			
		PV-S3200	3.2	1	13.9	Denmark	30 May 2012	NTR	4.01 / 4.05	✓ - ✓	- ✓	12/913			
Ningbo Ginlong Technologies Co, Ltd	China	GCI-1.5K	1.5	1	6.5	Denmark	6 September 2012	NTR		✓ ✓ - ✓	- ✓	12/1211			
		GCI-2K	2	1	8.7	Denmark	25 January 2012	NTR		✓ ✓ - ✓	- ✓	11/1939			
		GCI-3K	3	1	13	Denmark	16 August 2012	NTR		✓ ✓ - ✓	- ✓	11/1939			
		GCI-3.6K	3.6	1	15.6	Denmark	6 September 2012	NTR		✓ ✓ - ✓	- ✓	12/1211			
Omron Electronics AB	Japan	KP100L-OD-EU	10	3	14.5	Denmark	2 March 2012	NTR		✓ - ✓	- ✓	11/1703	Limited to 6kWp by factory setting for DK by request		
Power-One AG	Germany	UNO-2.0-I-OUTD	2	1	10	Denmark	6 August 2012	NTR	A.5.7.E / B.0.9.F / C.0.7.3	✓ - ✓	- ✓	12/862			
		UNO-2.5-I-OUTD	2.5	1	12	Denmark	6 August 2012	NTR	A.5.7.E / B.0.9.F / C.0.7.3	✓ - ✓	- ✓	12/862			
		PVI-3.0-TL-OUTD	3	1	14.5	Denmark	15 March 2012	NTR	C.0.0.3	✓ - ✓	- ✓	12/862			
		PVI-10.0-TL-OUTD	10	3	16.6	Denmark	15 March 2012	NTR	C.0.0.6	✓ - ✓	- ✓	12/862			
		PVI-12.5-TL-OUTD	12.5	3	20	Denmark	15 March 2012	NTR	C.0.0.6	✓ - ✓	- ✓	12/862			
		TRIO-20.0-TL	20	3	33	Denmark	15 March 2012	NTR	C.0.9.F	✓ - ✓	- ✓	12/862			
		TRIO-27.6-TL	27.6	3	45	Denmark	15 March 2012	NTR	C.0.9.F	✓ - ✓	- ✓	12/862			
Pow-Future		Jupiter-1500TL	1.5	1	7	Denmark	30 August 2012	NTR		✓ ✓ - ✓	- ✓	11-2139			
		Jupiter-2000TL	2	1	9	Denmark	30 August 2012	NTR		✓ ✓ - ✓	- ✓	11-2139			
		Jupiter-2500TL	2.5	1	12	Denmark	30 August 2012	NTR		✓ ✓ - ✓	- ✓	11-2139			
		Venus-3000TL	3	1	14.5	Denmark	30 August 2012	NTR		✓ ✓ - ✓	- ✓	11-2139			
		Venus-3600TL	3.68	1	16	Denmark	30 August 2012	NTR		✓ ✓ - ✓	- ✓	11-2139			
Q3 Energiedesign GmbH	Germany	QX3000	2.5	1	10.9	Denmark	26 July 2012	NTR	2.60	✓ - ✓	- ✓	12/1219			
		QX4200-DK	4.2	1	16	Denmark	26 July 2012	NTR	2.60	✓ - ✓	- ✓	12/1219	Limited to max 16 A/phase in software		
		QX12000-DK	12	3	16	Denmark	26 July 2012	NTR	1.39	✓ - ✓	- ✓	12/1219	Limited to max 16 A/phase in software		
REFUsol GmbH	Germany	802R08	8.25	3	12	Denmark	23 February 2012	NTR	27-1 4-S	✓ - ✓	- ✓	12/442	If limited to max 6 kW it has to be done in the configuration software and protected by installer password		
		802R010	10	3	14.5	Denmark	22 February 2012	NTR	27-1 4-S	✓ - ✓	- ✓	12/442			
		802R013	12.4	3	18	Denmark	22 February 2012	NTR	27-1 4-S	✓ - ✓	- ✓	12/442			
		802R017	16.5	3	23.9	Denmark	22 February 2012	NTR	27-1 4-S	✓ - ✓	- ✓	12/442			
		802R020	19.2	3	27.8	Denmark	22 February 2012	NTR	27-1 4-S	✓ - ✓	- ✓	12/442			
Samil Power Co., Ltd	China	SolarRiver 3400TL-D	3	1	16	Denmark	25 June 2012	NTR	1.00	✓ - ✓	- ✓	12/1090			
		SolarLake 10000TL	10	3	16	Denmark	17 July 2012	NTR	1.28/1.27/1.28	✓ - ✓	- ✓	12/87	If limited to max 6 kW it has to be done in the configuration software and protected by installer password		
		SolarLake 12000TL	12	3	19.2	Denmark	17 July 2012	NTR	1.28/1.27/1.28	✓ - ✓	- ✓	12/87	If limited to max 6 kW it has to be done in the configuration software and protected by installer password		
		SolarLake 15000TL	15	3	24	Denmark	17 July 2012	NTR	1.28/1.27/1.28	✓ - ✓	- ✓	12/87	If limited to max 6 kW it has to be done in the configuration software and protected by installer password		
		SolarLake 17000TL	17	3	25	Denmark	17 July 2012	NTR	1.28/1.27/1.28	✓ - ✓	- ✓	12/87	If limited to max 6 kW it has to be done in the configuration software and protected by installer password		
Sarachat Energy	China	ZZ-ZB 2.0	2	1	8.7	Denmark	12 April 2012	NTR		✓ ✓ - ✓	- ✓	11/1422			
		ZZ-ZB 3.0	3	1	13	Denmark	12 April 2012	NTR		✓ ✓ - ✓	- ✓	11/1422			
		ZZ-ZB 3.7	3.7	1	16	Denmark	12 April 2012	NTR		✓ ✓ - ✓	- ✓	11/1422			
		ZZ-ZB 5.0	5	2	10.9	Denmark	12 April 2012	NTR		✓ ✓ - ✓	- ✓	11/1422			
		ZZ-ZB 6.0	6	2	13	Denmark	12 April 2012	NTR		✓ ✓ - ✓	- ✓	11/1422			
		TLS-ZB 5.0	5	3	7.2	Denmark	12 April 2012	NTR		✓ ✓ - ✓	- ✓	11/1422			
		TLS-ZB 6.0	6	3	8.7	Denmark	12 April 2012	NTR		✓ ✓ - ✓	- ✓	11/1422			
		TLS-ZB 7.0	7	3	10.1	Denmark	12 April 2012	NTR		✓ ✓ - ✓	- ✓	11/1422			
		TLS-ZB 8.0	8	3	11.6	Denmark	12 April 2012	NTR		✓ ✓ - ✓	- ✓	11/1422			
		TLS-ZB 9.0	9	3	13	Denmark	12 April 2012	NTR		✓ ✓ - ✓	- ✓	11/1422			
		TLS-ZB 10.0	10	3	14.5	Denmark	12 April 2012	NTR		✓ ✓ - ✓	- ✓	11/1422			
		TLS-ZB 11.0	11	3	16	Denmark	12 April 2012	NTR		✓ ✓ - ✓	- ✓	11/1422			
Schüco International KG	Germany	SGI 9k	9	3	13	Denmark	20 June 2012	NTR	ARM V1.26, AC 1.20 DC 1.24	✓ - ✓	- ✓	11/274	If limited to max 6 kW it has to be done in the configuration software and protected by installer password		
		SGI 10k	10	3	14.5	Denmark	20 June 2012	NTR	ARM V1.26, AC 1.20 DC 1.24	✓ - ✓	- ✓	11/274	If limited to max 6 kW it has to be done in the configuration software and protected by installer password		
		SGI 12k	12.5	3	18.1	Denmark	20 June 2012	NTR	ARM V1.26, AC 1.20 DC 1.24	✓ - ✓	- ✓	11/274	If limited to max 6 kW it has to be done in the configuration software and protected by installer password		
		SGI 13.5k	13.5	3	19.5	Denmark	20 June 2012	NTR	ARM V1.26, AC 1.14 DC 1.07	✓ - ✓	- ✓	11/274			
		SGI 15k	15	3	21.7	Denmark	20 June 2012	NTR	ARM V1.26, AC 1.14 DC 1.24	✓ - ✓	- ✓	11/274			
		SGI 25k-02 Home	25	3	36.2	Denmark	20 June 2012	NTR	ARM V1.26, AC 1.14 DC 1.24	✓ - ✓	- ✓	11/274			
		SGI 30k-02 Home	30	3	47.7	Denmark	14 May 2012	NTR	ARM V1.26, AC 1.14 DC 1.24	✓ - ✓	- ✓	11/274			
		SGI 33k-02 Home	33	3	48.3	Denmark	14 May 2012	NTR	ARM V1.26, AC 1.14 DC 1.24	✓ - ✓	- ✓	11/274			
		SGI 2000plus-02	2	1	10.4	Denmark	20 June 2012	NTR	ARM V4.70 DSP V4.70	✓ - ✓	- ✓	11/274			
		SGI 2500plus-02	2.5	1	12.4	Denmark	20 June 2012	NTR	ARM V4.70 DSP V4.70	✓ - ✓	- ✓	11/274			
		SGI 3000plus-02	3	1	14.3	Denmark	20 June 2012	NTR	ARM V4.70 DSP V4.70	✓ - ✓	- ✓	11/274			
		SGI 1500Tplus-02	1.5	1	1.65	Denmark	1								

List of PV suncell inverters complying with the requirements in TF 3.2.1

Manufacturer	Nationality	Designation	Power AC	No. of phases	Current per fase	Factory settings	Approval	Expiry	Firmware	TF 3.2.1	EN 50438-DK	VDE-AR-N-4105	CE-compliant	Energinet.dk file (Barcode)	Comments
	[Country]	[type]	[kW]	[no.]	[A]		[date]	[date]	[version]	[✓]	[✓]	[✓]	[✓]	[✓]	
		iMars BG6KTR	6	3	10	Denmark	1 August 2012	NTR		✓	✓	-	✓		12/920
		iMars BG8KTR	8	3	13	Denmark	1 August 2012	NTR		✓	✓	-	✓		12/920
		iMars BG10KTR	10	3	15	Denmark	1 August 2012	NTR		✓	✓	-	✓		12/920
		iMars BG12KTR	12	3	20	Denmark	1 August 2012	NTR		✓	✓	-	✓		12/920
		iMars BG15KTR	15	3	24	Denmark	1 August 2012	NTR		✓	✓	-	✓		12/920
Shenzhen JingFuYuan Tech Co., Ltd	China	SOLTEKNIK-TL3000	3	1	13	Denmark	20 February 2012	NTR		✓	✓	-	✓		11/2290
		JSI-1500TL	1.5	1	7.9	Denmark	06 June 2012	NTR	V1.1	✓	✓	-	✓		11/2290
		JSI-2000TL	2	1	10.5	Denmark	12 March 2012	NTR		✓	✓	-	✓		12/593
		JSI-3000TL	3	1	13	Denmark	1 January 2011	NTR		✓	✓	-	✓		12/593
		JSI-3600TL	3.6	1	15.7	Denmark	12 March 2012	NTR		✓	✓	-	✓		12/593
		SunTwin3300TL	3.3	1	14.3	Denmark	06 June 2012	NTR	V1.4	✓	✓	-	✓		11/2290
		Suntree5000TL	5	3	7.3	Denmark	06 July 2012	NTR	V1.5	✓	✓	-	✓		12/593
		Suntree6000TL	6	3	8.7	Denmark	06 July 2012	NTR	V1.5	✓	✓	-	✓		12/593
		Suntree8000TL	8	3	11.6	Denmark	06 July 2012	NTR	V1.5	✓	✓	-	✓		12/593
		Suntree10000TL	10	3	14.5	Denmark	06 July 2012	NTR	V1.2	✓	✓	-	✓		12/593
		Suntree12000TL	12	3	17.4	Denmark	06 July 2012	NTR	V1.2	✓	✓	-	✓		12/593
Shenzhen Voltronic Power Technology Corp.	China	EnerSolar 3 kW	3	1	13	Denmark	13 July 2012	NTR	V00	✓	-	✓	✓		11/2462
Sinodan Solar	China	Macsol-TL1.5k	1.5	1	6.5	Denmark	11 April 2012	NTR		✓	✓	-	✓		12/691
		Macsol-TL2k	2	1	8.7	Denmark	11 April 2012	NTR		✓	✓	-	✓		12/691
		Macsol-TL3k	3	1	13	Denmark	11 April 2012	NTR		✓	✓	-	✓		12/691
		Macsol-TL3.6k	3.6	1	15.6	Denmark	6 August 2012	NTR		✓	✓	-	✓		12/691
SMA Solar Technology AG	Germany	SB 1200	1.2	1	5.2	Denmark	20 February 2012	NTR	4.00	✓	-	✓	✓		10/6898
		SB 1300TL-10	1.3	1	5.7	Denmark	12 June 2012	NTR	4.00	✓	-	✓	✓		10/6898
		SB 1700	1.7	1	7.4	Denmark	20 February 2012	NTR	4.00	✓	-	✓	✓		10/6898
		SB 1600TL-10	1.6	1	7	Denmark	24 February 2012	NTR	4.00	✓	-	✓	✓		10/6898
		SB 2100TL	2.1	1	9.1	Denmark	20 February 2012	NTR	4.00	✓	-	✓	✓		10/6898
		SB 2000HF-30	2	1	8.7	Denmark	20 February 2012	NTR	2.30	✓	-	✓	✓		10/6898
		SB 2500HF-30	2.5	1	10.9	Denmark	24 February 2012	NTR	2.30	✓	-	✓	✓		10/6898
		SB 3000HF-30	3	1	13	Denmark	20 February 2012	NTR	2.30	✓	-	✓	✓		10/6898
		SB 2500TLST-21	2.5	1	10.9	Denmark	12 June 2012	NTR	2.00	✓	-	✓	✓		10/6898
		SB 3000TLST-21	3	1	13.1	Denmark	12 June 2012	NTR	2.00	✓	-	✓	✓		10/6898
		SB 2500	2.5	1	11	Denmark	20 February 2012	NTR	4.00	✓	-	✓	✓		10/6898
		SB 3000	3	1	13	Denmark	20 February 2012	NTR	4.00	✓	-	✓	✓		10/6898
		SB 3000TL-21	3	1	13	Denmark	20 February 2012	NTR	1.50	✓	-	✓	✓		10/6898
		SB 3300-11	3.6	1	15.7	Denmark	20 February 2012	NTR	1.00	✓	-	✓	✓		10/6898
		SB 3600TL-21	3.68	1	16	Denmark	24 July 2012	NTR	2.10	✓	-	✓	✓		10/6898
		SB 4000TL-21	4	1	16	Denmark	21 August 2012	NTR	3.00	✓	-	✓	✓		12/1384 If limited to max 3.68 kW it has to be done in the configuration software and protected by installer password
		STP 5000TL-20	5	3	7.3	Denmark	13 August 2012	NTR	2.01	✓	-	✓	✓		10/6898
		STP 6000TL-20	6	3	8.7	Denmark	13 August 2012	NTR	2.01	✓	-	✓	✓		10/6898
		STP 7000TL-20	7	3	10.2	Denmark	13 August 2012	NTR	2.01	✓	-	✓	✓		10/6898
		STP 8000TL-10	8	3	11.5	Denmark	24 February 2012	NTR	2.31	✓	-	✓	✓		10/6898 If limited to max 6 kW it has to be done in the configuration software and protected by installer password
		STP 8000TL-20	8	3	11.6	Denmark	13 August 2012	NTR	2.01	✓	-	✓	✓		10/6898
		STP 9000TL-20	9	3	13.1	Denmark	13 August 2012	NTR	2.01	✓	-	✓	✓		10/6898
		STP 10000TL-10	10	3	14.4	Denmark	24 February 2012	NTR	2.31	✓	-	✓	✓		10/6898 If limited to max 6 kW it has to be done in the configuration software and protected by installer password
		STP 12000TL-10	12	3	17.3	Denmark	24 February 2012	NTR	2.31	✓	-	✓	✓		10/6898 If limited to max 6 kW it has to be done in the configuration software and protected by installer password
		STP 15000TL-10	15	3	21.7	Denmark	24 February 2012	NTR	2.31	✓	-	✓	✓		10/6898 If limited to max 6 kW it has to be done in the configuration software and protected by installer password
		STP 17000TL-10	17	3	24.5	Denmark	24 February 2012	NTR	2.31	✓	-	✓	✓		10/6898 If limited to max 6 kW it has to be done in the configuration software and protected by installer password
		STP 15000TLEE-10	15	3	21.7	Denmark	12 June 2012	NTR	1.00	✓	-	✓	✓		10/6898
		STP 2000TLEE-10	20	3	29	Denmark	12 June 2012	NTR	1.00	✓	-	✓	✓		10/6898
		STP 15000TLHE-10	15	3	21.7	Denmark	12 June 2012	NTR	1.00	✓	-	✓	✓		10/6898
		STP 20000TLHE-10	20	3	28.9	Denmark	21 December 2011	NTR	1.00	✓	-	✓	✓		10/6898
SolarEdge Technologies	Israel	SE3000	3	1	13	Denmark	23 January 2012	NTR		✓	✓	-	✓		10/6879
		SE3300	3.3	1	14.3	Denmark	23 January 2012	NTR		✓	✓	-	✓		10/6879
		SE3500	3.5	1	15.2	Denmark	23 January 2012	NTR		✓	✓	-	✓		10/6879
		SE4000-16A limited	4	1	16	Denmark	23 January 2012	NTR		✓	✓	-	✓		10/6879 Limited to max 16 A/phase
		SE7k	7	3	11.5	Denmark	23 January 2012	NTR		✓	✓	-	✓		10/6879 Limited to max 6 kW using firmware code 34 "Denmark Residential"
		SE8k	8	3	13.5	Denmark	23 January 2012	NTR		✓	✓	-	✓		10/6879 Limited to max 6 kW using firmware code 34 "Denmark Residential"
		SE9k	9	3	1										

List of PV suncell inverters complying with the requirements in TF 3.2.1

Manufacturer	Nationality	Designation	Power AC	No. of phases	Current per fase	Factory settings	Approval	Expiry	Firmware	TF 3.2.1	EN 50438-DK	VDE-AR-N-4105	CE-compliant	Energinet.dk file (Acadre)	Comments
	[Country]	[type]	[kW]	[no.]	[A]		[date]	[date]	[version]	[✓]	[✓]	[✓]	[✓]		
		SolarWorld Piko 5.5	5.5	3	8	Denmark	3 January 2012	NTR	V04.00	✓	-	✓	✓	11/1239	
		SolarWorld Piko 7.0	7	3	10	Denmark	26 April 2012	NTR	V04.00	✓	-	✓	✓	11/1239	By factory selection "DK" limited to 6kW
		SolarWorld Piko 7.0 AD	7	3	10	Denmark	26 April 2012	NTR	V04.00	✓	-	✓	✓	11/1239	By factory selection "DK" limited to 6kW
		SolarWorld Piko 8.3	8.3	3	12	Denmark	3 January 2012	NTR	V04.00	✓	-	✓	✓	11/1239	If limited to max 6 kW it has to be done in the configuration software and protected by installer password
		SolarWorld Piko 10.1	10	3	14.6	Denmark	3 January 2012	NTR	V04.00	✓	-	✓	✓	11/1239	If limited to max 6 kW it has to be done in the configuration software and protected by installer password
Solutronic AG	Germany	SolPlus 25	2.5	1	8.7	Denmark	2 April 2012	NTR	2.60	✓	-	✓	✓	10/7265	
		SolPlus 35-DK	3	1	12.5	Denmark	2 April 2012	NTR	2.60	✓	-	✓	✓	10/7265	Limited to max 3 kW in configuration software and protected by installer password
		SolPlus 100-DK	10	3	16	Denmark	6 March 2012	NTR	1.39	✓	-	✓	✓	10/7265	If limited to max 6 kW it has to be done in the configuration software and protected by installer password
		SolPlus 120	12	3	17.4	Denmark	17 August 2012	NTR	1.39	✓	-	✓	✓	10/7265	
Steca Elektronik GmbH	Germany	StecaGrid 3000	3	1	16	Denmark	9 February 2012	NTR		✓	-	✓	✓	11/1705	
		StecaGrid 3600	3.6	1	16	Denmark	9 February 2012	NTR		✓	-	✓	✓	11/1705	
		StecaGrid 8000+	8	3	11.6	Denmark	22 March 2012	NTR		✓	-	✓	✓	11/1705	If limited to max 6 kW it has to be done in the configuration software and protected by installer password
		StecaGrid 10000+	9.9	3	14.3	Denmark	22 March 2012	NTR		✓	-	✓	✓	11/1705	If limited to max 6 kW it has to be done in the configuration software and protected by installer password
Sunways AG	Germany	NT 2500	2.5	1	10.9	Denmark	23 January 2012	NTR		✓	-	✓	✓	10/7137	
		NT 3000	3.0	1	13	Denmark	23 January 2012	NTR		✓	-	✓	✓	10/7137	
		NT 3700	3.7	1	16	Denmark	23 January 2012	NTR		✓	-	✓	✓	10/7137	
		NT 10000	10	3	14.5	Denmark	23 January 2012	NTR		✓	-	✓	✓	10/7137	
		NT 11000	11	3	16	Denmark	23 January 2012	NTR		✓	-	✓	✓	10/7137	
		NT 12000	12	3	17.4	Denmark	23 January 2012	NTR		✓	-	✓	✓	10/7137	
		AT 2700	2.7	1	11.7	Denmark	24 July 2012	NTR		✓	-	✓	✓	11/2273	
		AT 3000	3	1	13.0	Denmark	24 July 2012	NTR		✓	-	✓	✓	11/2273	
		AT 3600	3.6	1	15.6	Denmark	24 July 2012	NTR		✓	-	✓	✓	11/2273	
Suzhou Omnik New Energy Co.Ltd	China	Omniksol-1.5-TL	1.5	1	9	Denmark	19 September 2012	NTR		✓	✓	-	✓	12/362	
		Omniksol-2.0-TL	2	1	12	Denmark	19 September 2012	NTR		✓	✓	-	✓	12/362	
		Omniksol-3.0-TL	3	1	13	Denmark	28 June 2012	NTR		✓	✓	-	✓	12/362	
Swea	Holland	UWT-I-250	0.25	1	1	Denmark	25 April 2012	NTR		✓	✓	-	✓	12/774	Max 3.68kVA per plant
		UWT-I-1KW solar	1	1	4	Denmark	25 April 2012	NTR		✓	✓	-	✓	12/774	
Trannergy Power Electronics	China	PVI1800TL	1.5	1	7.7	Denmark	28 June 2012	NTR	E1.00	✓	-	✓	✓	12/1087	
		PVI2300TL	2	1	10.2	Denmark	28 June 2012	NTR	E1.00	✓	-	✓	✓	12/1087	
		PVI3200TL	2.8	1	14.2	Denmark	28 June 2012	NTR	E1.00	✓	-	✓	✓	12/1087	
		PVI110KTL	10	3	14.5	Denmark	13 September 2012	NTR	0101	✓	-	✓	✓	12/1087	
		PVI112KTL	12	3	17.4	Denmark	13 September 2012	NTR	0101	✓	-	✓	✓	12/1087	
		PVI117KTL	17	3	24.6	Denmark	13 September 2012	NTR	0101	✓	-	✓	✓	12/1087	
Vertipower	China	Vertipower VPI 1500 TL	1.5	1	6.5	Denmark	14 December 2011	NTR		✓	✓	-	✓	11/760	
		Vertipower VPI 2000 TL	2	1	8.7	Denmark	14 December 2011	NTR		✓	✓	-	✓	11/760	
		Vertipower VPI 3000 TL	3	1	13	Denmark	14 December 2011	NTR		✓	✓	-	✓	11/760	
		Vertipower VPI 10.000 TL	10	3	16	Denmark	24 April 2012	NTR		✓	✓	-	✓	11/760	If limited to max 6 kW it has to be done in the configuration software and protected by installer password
		Vertipower VPI 12.000 TL	12	3	19	Denmark	24 April 2012	NTR		✓	✓	-	✓	11/760	
		Vertipower VPI 18.000 TL	18	3	29	Denmark	24 April 2012	NTR		✓	✓	-	✓	11/760	
		Vertipower VPI 20.000 TL	20	3	32	Denmark	24 April 2012	NTR		✓	✓	-	✓	11/760	
Wuhan Powfuture Sci and Tech Co.,Ltd,	China	Jupiter-1500TL	1.5	1	7	Denmark	30 August 2012	NTR		✓	✓	-	✓	11/2139	
		Jupiter-2000TL	2	1	9	Denmark	30 August 2012	NTR		✓	✓	-	✓	11/2139	
		Jupiter-2500TL	2.5	1	12	Denmark	30 August 2012	NTR		✓	✓	-	✓	11/2139	
		Venus-3000TL	3	1	14.5	Denmark	30 August 2012	NTR		✓	✓	-	✓	11/2139	
		Venus-3600TL	3.68	1	16	Denmark	20 August 2012	NTR		✓	✓	-	✓	11/2139	

Standards

TF 3.2.1	Technical Regulation 3.2.1 for electricity-generation plants rated up to and including 16 A per phase, single or multi phase (Version 2.1)
EN 50438-DK	Requirements for the connection of micro-generators in parallel with public low-voltage distribution networks (Version 2007)
VDE-AR-N-4105	DE Recommendation - Alternative to TF 3.2.1
CE-compliant	Safety etc.
Firmware	Approved firmware

Note:

NTR = Next Technical Revision (Future)