



- Tcolector - T retorn acumuladors > +7°C = marxa bomba
- Tcolector - T retorn acumuladors > +4°C => per bomba
- Si Tcolector > 45 °C => arranc bomba
- Si Tcolector < 45 °C => parada bomba
- Si Tcolector < 90 °C => parada bomba